


**CERTIFICATE FOR SAFE DRINKING WATER AND
SANITARY CONDITION****No.TH0/HSN/101/2026-27****Dated:15-06-2026**

It is certified that an inspection team headed by **Dr.VIJAY GORUR N.D, TALUK HEALTH OFFICER, HASSAN** (Name of Officers with designation) from **Department of health and family welfare, Hassan** (Name of Department/ Office) inspected the **St. Joseph's English Medium Higher Primary School, Saraswathipuram, Salagame Road, Hassan - 573201** (Name & Address of the school) on **12/06/2026** (date of inspection), checked the water test report bearing **No.DHL/WATER/BAC/20/2026-27** Dated **15/06/2026** certified that the **St. Joseph's English Medium Higher Primary School, Saraswathipuram, Salagame Road, Hassan - 573201** has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of **12/06/2028**.

Signature with Seal


Dr. VIJAY GORUR, MBBs
Reg.No. 45874
Taluk Health Officer
Hassan Taluk**Name :****Dr.Vijay Gorur N D****Designation :****Taluk Health officer, Hassan****Name & Address****Dept.Health and Family Welfare****of the Office :****Hassan****To****St. Joseph's English Medium Higher Primary School
Saraswathipuram, Salagame Road,
Hassan - 573201****(Name & Address of the Institution)**

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate.


**St. Joseph's English Medium
Higher Primary School
Hassan- 573 201**
**Secretary & Treasurer
KARNATAKA JESUIT EDUC. SOCIETY**

No/DHL/WATER/BAC /20 /2026-27

office of the Dist. Surveillance Office
District surveillance Unit, Hassan
date:15 /06/2026

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER SAMPLE

SAMPLE SENT BY	Sample No.	Source And Particulars of Water Samples	H2S. Test	MPN Count	D.C. Test	S.P.P	N.S.P.P	NSPP & FC
PHC/CHC/GH..... TALUK HASSAN, HSN DIST								
<u>NOTE</u> <u>H2S Test:-</u> Preliminary Test in H2S Media	116	WATER SOURCE : BOREWELL WATER St. Joseph school ground, Hassan, UPHC KRISHNA HOSPITAL		0/100 ml		yes		
<u>MPN COUNT:-</u> Most probable number of Bacteria per 100ml of water	117	WATER SOURCE : TAP WATER St. Joseph's English Medium Higher Primary School, Saraswathipuram, Salagame Road, Hassan, UPHC M KRISHNA HOSPITAL		0/100 ml		yes		
<u>D.C. Test:-</u> Differential Coliform Test	118	WATER SOURCE : PURIFIED WATER Hoysala Boy's Hostel filter water, Karekere ,CHC SHANTHIGRAMA		0/100 ml		yes		
<u>S.P.P:-</u> water is Satisfactory for potable purpose	119	WATER SOURCE : PURIFIED WATER Hoysala Boy's Hostel filter water, Karekere ,CHC SHANTHIGRAMA		0/100 ml		yes		
<u>N.S.P.P</u> Water is not satisfactory for potable purpose								
<u>NSPP & F.C:-</u> Water is not satisfactory for drinking purpose and E.Coli found								

Dr. Vijay GORUR, MBBS
Medical Microbiologist
District Surveillance Unit, Hassan
15/6/26

Saladog
Secretary & Treasurer
KARNATAKA JESUIT EDUC. SOCIETY

Dr. Vijay GORUR, MBBS
Reg.No. 45874
Taluk Health Officer
Hassan Taluk

Sd/=

Dist.Surveillance Officer

District Surveillance Unit, Hassan

HEAD MASTER

St. Joseph's English Medium
Higher Primary School
Hassan- 573 201



**ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ ಇಲಾಖೆ
ಜಿಲ್ಲಾ ಕುಡಿಯುವ ನೀರು ಪರೀಕ್ಷಾ ಪ್ರಯೋಗಾಲಯ, ಹಾಸನ**

ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರವರ ಕಛೇರಿ, ಗ್ರಾಮೀಣ
ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ ಇಲಾಖೆ,
ಹಾಸನ ವಿಭಾಗ, ಹಾಸನ 573201

eerdwsd.hsn@gmail.com
rdwsd.wqmsh.hassanlab@gmail.com
Phone No.08172-261640

WATER SAMPLE TEST REPORT

1.District :	Hassan	5.Sample collection date:	29.05.2026
2.Taluk:	Hassan	6.Sample recieved date:	29.05.2026
3.Village/Habitation:	Saraswathipuram	7.Source:	Filter Water
4.Grama Panchayath:	-	8.Name and address:	St. Joseph's English Medium School, Salagame Road, Saraswathipuram, Hassan.

Sl.No	Characteristic	Requirement (Acceptable limit)	Permissible Limit in the Absence of Alternate Source	Method of Test,Ref to	Result
1	Colour,Hazen units	5	15	IS 3025(Part-4):2021	1
2	Odour	Agreeable	Agreeable	IS 3025(Part -5 &6):2018	Agreeable
3	Taste	Agreeable	Agreeable	IS 3025(Part -8):1983 (RA 2017)	Agreeable
4	Ph, Value	6.5-8.5	No Relaxation	IS 3025 (Part-11):2022	7.02
5	Turbidity, NTU	1	5	IS 3025 (Part -10):2023	1
6	Total Dissolved solid, mg/l	500	2000	IS 3025 (Part -16):2023	48
7	Conductivity us/cm	-	-	IS 3025 (Part -14):2019	76
8	Calcium(as Ca) mg/l	75	200	IS 3025 (Part- 40):2024	<8
9	Chloride (as Cl) mg/l	250	1000	IS 3025 (Part -32):1988	7.99
10	Fluoride (as F)mg/l	1	1.5	APHA 24th Edition:4500 F-D	<0.1
11	Iron (as Fe)mg/l	1	No Relaxation	IS 3025 (Part -53):2024	<0.1
12	Magnesium (as Mg) mg/l	30	100	IS 3025 (Part -46):2023	<5
13	Nitrate (as NO3) mg/l	45	No Relaxation	APHA 24th Edition:4500 NO3-B	<0.5
14	Sulphate (as SO4) mg/l	200	400	IS 3025 (Part -24/sec 1):2022	<1
15	Total Alkalinity mg/l	200	600	IS 3025 (Part -23):2023	15
16	Total Hardness (as CaCO3)mg/l	200	600	IS 3025 (Part -21):2009	<20

Inference:The analyzed values for the above parameters are within the limit as per IS-10500:2012.

Date:03.06.2026
Place: Hassan

Praveena H.S.
Chemist
District Water Testing Laboratory
R.D.W. & S.D Hassan.



HEAD MASTER
St. Joseph's English Medium
Higher Primary School
Hassan- 573 201

Secretary & Treasurer
KARNATAKA JESUIT EDUC. SOCIETY